



The GWR System – Indirect Potable Reuse as a New Water Source


Mehul Patel, P.E. GWRS Process Manager Orange County Water District

Presented To University of South Florida February 15, 2010














Lime clarification, sand filtration, GAC (BAC), Chlorine disinfection First RO treatment of recycled water in 1977





Blend of RO/GAC/Deep well water 15 MGD 1980-2000

UV added for NDMA destruction in 2001 Research into RO and pretreatment 1977-2000 Planning for Groundwater Replenishment (GWR System) 1995-2002

Interim Water Factory 5 MGD (6.9 million m³/yr)

MF/RO/UV 2004-2006














| Joint Partnership | | | | | | | | |
|---|---|---|--|--|--|--|--|--|
| OCSD: | Wastewater Collection and Disposal | , Source Control, Treatment | | | | | | |
| OCWD: Manages and protects the Orange County Groundwater Basin | | | | | | | | |
| P | Partnership since 1972 for Wastewater Reclamation | | | | | | | |
| Source Control | OCSD | OCWD | | | | | | |
| Sewage | | atment Advanced Water Purification Reuse | | | | | | |











Reverse Osmosis System



70 MGD Reverse Osmosis System Hydranautics ESPA-2 Membranes Fifteen 3-stage array units (78:48:24) each sized at 5 mgd Pacouver Pate: 95%

Recovery Rate: 85% Flux of 12 gfd Removes dissolved minerals, viruses, and organic compounds (incl. pharmaceuticals) Pressure range: 180 - 230 psi
15,750 membrane elements Two CIP systems

Ultraviolet/Advanced Oxidation System P10.

70 MGD Trojan UVPhox System

Low Pressure – High Output lamp system

Destroys trace organics Uses Hydrogen Peroxide to form an Advanced Oxidation Process

UV system given a 4-log virus removal credit to meet CA DPH Title 22 criteria for recycled water

Where Does GWR System Water Go?

Water is returned to groundwater basin Half (35 MGD) is sent to seawater intrusion barrier Half (35 MGD) is sent to recharge basins in Anaheim





Regulatory Oversight alifornia Dept. of Public Health (CDPH) establishes excelling criteria Treatment and quality TOC limit Tock limit Travel time Blending Regional Water Quality Control Board issues reclamation permit Regional Board incorporates CDPH recommendati Into permit Regional Board incorporates CDPH recommendations into permit CDPH public hearing - Feb 2003 Regional Board permit - Feb 2004 Incorporate CDPH recommendations 100% RO, AOP Meet drinking water standards Monitor for unregulated contaminants Blend with storm water and imported water 75% recycled water blend for injected water can increase to 100% once demonstrate receiving and the deciver of the constrate receiving and the deciver of the deciver of the constrate receiving and the deciver of the constrate receiving and the deciver of 2-1-4



Multiple Barriers Protect Public Health

- Microbial contaminants
 - MF removes bacteria and protozoa RO removes viruses, bacteria
 - UV inactivates microbes, prevents replication
 - Retention time in groundwater
- Chemical contaminants –

- Source control prevents introduction of contaminants
- MF removes particles, suspended solids
- RO removes dissolved salts, metals, organics, including pharmaceuticals, endocrine disruptors
- UV with hydrogen peroxide destroys small organics
- Groundwater provides buffering, biodegradation, ion exchange

Process Control Points

Key points in treatment process monitored for failure by on line instrumentation Online sensors can detect treatment lapses Examples include:

- Turbidity through MF Pressure decay test with MF Conductivity through RO TOC through RO UVT into UV AOP UV power delivered
- pH through decarbonation pH through lime addition



Source Control

Orange County Sanitation District "enhanced source control"

- Regulate discharges into sewer to prevent contamination
- First step in producing drinking water, first barrier
- OCWD helps identify compounds of concern and efficacy of
- advanced treatment

 Divert non-reclaimable wastes to
- different plant





Appointed By National Water Research Institute in 2004 as a requirement of the GWRS plant operating permit Leading Experts in Hydrogeology, Chemistry, Toxicology, Microbiology,

- Engineering, Public Health, Public Communications and Environmental Protection
- Review Operations, Monitoring and Water Quality
- Panel Makes Recommendations to OCWD and Regulatory Agencies to Assure Quality and Reliability

Water Quality Produced by GWRS

- Meets all drinking water standards
- Influent TDS 1000 mg/L, RO product <30 mg/L</p>
- Influent TOC 11-12 mg/L, product water <0.15 mg/L</p>
- Pharmaceuticals removed to non detect (ng/L RDLs)
 Other CECs also effectively removed by RO
- NDMA destroyed by UV
- 1,4-dioxane source control and removed by RO, AOP
- ND to trace THMs

1 4

Best water available for aquifer replenishment

| GWRS Water Quality | | | | | | | |
|---------------------------|--------------------|-------------------------------|-----------------------|-------------------------|---------------|--|--|
| | | | | | | | |
| Parameter | Sample Location | Method | Permit Requirement | Reportable Detection | Actual Values | | |
| | RO Permeate | 5910B | >90% | | 98.80% | | |
| Turbidity | RO Permeate | Automated Plant Monitoring | | | 0.18 NTU | | |
| Total Recycled Water Flow | Final Product | Plant Monitoring | <70 mgd | N/A | N/A | | |
| Total Nitrogen | Final Product | 4500NO3F | 5 mg/L | 0.4 mg/L | 1.7 mg/L | | |
| Total Organic Carbon | Final Product | 5310C | 0.5 mg/L | 0.01 mg/L | 0.19 mg/L | | |
| Total Coliform | Final Product | 9221B | 2.2 MPN /100 ml | 2 MPN /100 ml | ND | | |
| | Final Product | Automated Plant Monitoring | 6 - 9 | | 8.22 | | |
| Electrical Conductivity | Final Product | 2510B | N/A | 1 um/cm | 80.96 um/cm | | |



| Hormones | Result (ng/L) | Detection Limit (ng/L) |
|---------------------|---------------|------------------------|
| Diethylstilbestrol | ND | 10 |
| Progesterone | ND | 10 |
| 7a-Ethynylestradiol | ND | 10 |
| 7b-Estradiol | ND | 10 |
| 17a-Estradiol | ND | 10 |
| Estriol | ND | 10 |
| estosterone | ND | 10 |
| pitestosterone | ND | 10 |
| Estrone | ND | 10 |



| Eeed Water to GWRS | | | | | | | |
|--------------------|---------------|------------------------|--|--|--|--|--|
| Pharmaceuticals | Result (ng/L) | Detection Limit (ng/L) | | | | | |
| Triclosan | 510 | 1 | | | | | |
| Ibuprofen | 1000 | 5 | | | | | |
| Gemfibrizol | 4300 | 1 | | | | | |
| Sulfamexthoxazole | 2100 | 1 | | | | | |
| Primidone | 140 | 1 | | | | | |
| DEET | 77.7 | 1 | | | | | |
| Ciprofloxacin | 820 | 100 | | | | | |
| Carbamazepine | 260 | t | | | | | |
| Azithromycin | 1200 | 5 | | | | | |
| Acetominophen | 35.9 | 10 | | | | | |
| Caffeine | 460 | 3 | | | | | |



| Pharmaceutical Results for Final Product Water | | | | | | | |
|---|--------------------|------------------------|-----------------------|-------------------------|------------------|--|--|
| Parameter | Sample Location | Method | Permit Requirement | Reportable Detection | Actual Values | | |
| Pharmaceuticals and Other Substances | | | | | | | |
| Acetaminopen | Final Product | Pharma | N/A | 10-20 ng/L | ND | | |
| Azithromycin | Final Product | Pharma | N/A | 1 ng/L | ND | | |
| Caffeine | Final Product | Pharma | N/A | 3 ug/L | ND | | |
| Carbamazepine | Final Product | Pharma | N/A | 1 ng/L | ND | | |
| Ciprofloxacin | Final Product | Pharma | N/A | 10-150 ng/L | ND | | |
| Ethylenediamine Tetra-Acetic Acid (EDTA) | Final Product | No developed Method | N/A | N/A | N/A | | |
| Gemfibrozil | Final Product | Pharma | N/A | 1 ng/L | ND | | |
| Ibuprofen | Final Product | Pharma | N/A | 1 ng/L | ND | | |
| lodinated Contrast Media | Final Product | No developed Method | N/A | N/A | N/A | | |
| Lipitor | Final Product | No developed Method | N/A | N/A | N/A | | |
| Methadone | Final Product | No developed Method | N/A | N/A | N/A | | |
| Morphine | Final Product | No developed Method | N/A | N/A | N/A | | |
| Salicylic Acid | Final Product | No developed Method | N/A | N/A | N/A | | |
| Triclosan | Final Product | Pharma | N/A | 1-5 ng/L | ND | | |




| | C Res | | | | |
|--|--------------------|---------------------|-----------------------|-------------------------|------------------|
| Parameter | Sample Location | Method | Permit Requirement | Reportable Detection | Actual Values |
| Endorcrine Disrupting Chemicals and | Pharmaceuticals | | | | |
| Hormones | | | | | |
| 17a-Ethynyl Estradiol ²⁷ | Final Product | Hormones | N/A | 10 ng/L | ND |
| 17-b Estradiol | Final Product | Hormones | N/A | 10 ng/L | ND |
| Estrone | Final Product | Hormones | N/A | 10 ng/L | ND |
| "Industrial" Endocrine Disruptors | | | | | |
| Bisphenol A | Final Product | Phenols | N/A | 1 ug/L | ND |
| Nonylphenol | Final Product | Phenols | N/A | 1 ug/L | ND |
| Nonylphenol Polyethoxylate ²⁸ | Final Product | Phenols | N/A | 10-30 ug/L | ND |
| Octylphenol ²⁹ | Final Product | Phenols | N/A | 2 ug/L | ND |
| Octylphenol Polyethoxylate | Final Product | No developed method | N/A | N/A | N/A |
| Polybrominated Diphenyl Ethers | Final Product | 525 | N/A | 0.1 ug/L | ND |




| in Final Product Water | | | | | | |
|---------------------------------|--------------------|---------------------------------------|-----------------------|-------------------------|------------------|--|
| Parameter | Sample Location | Method | Permit Requirement | Reportable Detection | Actual Values | |
| | UNRE | GULATED CHEMIC | CALS | | | |
| Boron | Final Product | 200.7 | 1 mg/L' | 0.1 mg/L | 0.25 mg/L | |
| Hexavalent Chromium (dissolved) | Final Product | 218.6 | N/A | 0.2-1 ug/L | ND | |
| Vanadium | Final Product | 200.7 | 50 ug/L* | 0.5 ug/L | ND | |
| Dichlorodifluoromethane | Final Product | 524.2 | 1 mg/L | 0.5 ug/L | ND | |
| Ethyl tert-butyl ether | Final Product | 524.2 | N/A | 1 ug/L | ND | |
| Tertiary-amyl methyl ether | Final Product | 524.2 | N/A | 1 ug/L | ND | |
| Tert-butyl alcohol | Final Product | 524.2 | 12 ug/L' | 2 ug/L | ND | |
| 1,2,3-Trichloropropane | Final Product | TCP-LOW | 0.005 ug/L' | 0.005 ug/L | ND | |
| n-Nitrosodimethylamine (NDMA) | Final Product | Isotopic Dilution – GC/MS/MS-CI | 10 ng/L' | 2 ng/L | ND | |
| 1,4-Dioxane | Final Product | Purge andTrap GC/MS | 3 ug/L" | 1 ug/L | ND | |









Operational since January 2008

| GWR System Actual Unit Water Costs (2009) | | | | | | | | | |
|---|---------------|--------|------------|---------|-----------|----------|--|--|--|
| | | August | September | October | November | December | | | |
| Electricity | July \$146 | \$127 | \$131 | \$99 | \$118 | \$106 | | | |
| Chemicals | \$62 | \$74 | \$64 | \$68 | \$63 | \$69 | | | |
| Labor | \$115 | \$107 | \$112 | \$107 | \$156 | \$125 | | | |
| Plant Maintenance | \$52 | \$39 | \$71 | \$58 | \$72 | \$72 | | | |
| R&R Fund Contribution (\$4.5 Million Annually) | \$67 | \$63 | \$65 | \$64 | \$95 | \$70 | | | |
| Debt Service (\$11.5 Million Annually) | \$170 | \$162 | \$611 | \$165 | \$242 | \$180 | | | |
| Subtotal | \$612 | \$573 | \$656 | \$562 | \$746 | \$622 | | | |
| MWD LRP Subsidy (1) | -\$14 | -\$121 | -\$121 | -\$121 | -\$121 | -\$121 | | | |
| OCSD contribution to maintenance cost (2) | -\$7 | -\$7 | -\$7 | -\$7 | -\$11 | -\$8 | | | |
| Total (\$/AF) | \$591 | \$445 | \$483 | \$434 | \$614 | \$493 | | | |
| Production (AF) | 5633 | 5910 | 5751 | 5820 | 3963 | 5334 | | | |
| (1) MWD LRP Subsidy of \$121/at (2) Currently estimated at \$500,0 | | | t 5,000 af | of wate | er produc | ed. | | | |



How Does the Water Cost Compare?

Comparable to alternative sources

- One Acre Foot (AF) = water for two families/yr
- Typical OC retail water rate >\$900/AF in 2009
- GWR \$560/AF (\$1.72/1000 gal) with grants and subsidies \$121/AF operating subsidy from MWD (regional water importer)
- GWR \$850/AF (\$2.60/1000 gal) without grants/subsidies Raw MWD water for recharge:
- \$536/AF increasing to \$637 (\$1.95/1000 gal) by Jan 2011 Treated MWD water for direct use: \$753/AF increasing to \$899 (\$2.75/1000 gal) by Jan 2011



Even Indirect Projects Have Failed to Gain Public Support

- San Diego "toilet to tap" rejected twice Los Angeles – DWP East Valley project
- Upper San Gabriel
- Dublin/San Ramon
- Queensland, Australia







What Have We Learned from Potable Reuse in OC?

Public can accept potable reuse if:

- Need is clear
- Safety is assured multiple barriers
 Quality is better than alternatives
 Public health agencies have
- continuing oversight
- Independent scientific review
 Outreach is effective and ongoing
- Politicians and community leaders make commitment
 The more provide understand the
- The more people understand the more they accept the idea







100% support from businesses and major environmental groups

Support from several health experts, medical doctors hospitals, pharmacists and scientists

Educational, religious, police, fire leaders,

minority leaders and more than 200 community



elected officials

PUBLIC OUTREACH PROCESS FOR GWRS



Meetings with All Elected Officials... Local, State and National

- Presentations to Community Groups, Organizations, Clubs, etc... Over 1,500 to Date
- Tours of the Advanced Water Purification Plant
- Tours of the Recharge Facilities
 Press Releases, Editorial Board Briefings, Briefings for Each New Reporter

Cable/Local TV Appearances

Widespread Unplanned T **Potable Reuse**

Most major water supplies have wastewater component OC depends on Colorado River, State
 Water Project, Santa Ana River (wastewater dominated)

- Wastewater dominated)
 Philadelphia Schuylkill River
 Cincinnati Ohio River
 Washington D.C. Occoquan River
 Worldwide rivers receive wastewater and provide drinking water



-


.

| EARLY INDIRECT POTABLE REUSE PROJECTS | | | | | | | | |
|--|--------------|------------|----------------------------------|-------------|--|--|--|--|
| Project | <u>Start</u> | Size (MGD) | <u>Treatment</u> | <u>Use</u> | | | | |
| Whittier Narrows, CA | 1963 | 40 | Tertiary | Percolation | | | | |
| South Lake Tahoe, CA | 1966 | 6.5 | Tertiary, GAC | Injection | | | | |
| Windhoek, Africa | 1969 | 4.5 | Advanced without membranes | DPR | | | | |
| Water Factory 21, OCWD | 1976 | 5 | RO,UV | Injection | | | | |
| Upper Occoquan, VA | 1981 | 24 | Tertiary, GAC | Reservoir | | | | |
| El Paso, TX | 1986 | 6.5 | Tertiary, GAC | Injection | | | | |
| West Basin, LA | 1996 | 5 | MF, RO | Injection | | | | |
| Scottsdale, AZ | 2002 | 9 | MF, RO | Injection | | | | |

| WATER | | | | | | | | | |
|---|--------------|------------|------------|---------------------------|--|--|--|--|--|
| | FIC/ | | PROJEC | TS | | | | | |
| Project | <u>Start</u> | Size (MLD) | Treatment | <u>Use</u> | | | | | |
| GWR System, OCWD | 2008 | 70 | MF, RO, UV | Percolation/ Injection | | | | | |
| Singapore NEWater | 2003 | 9 | MF, RO, UV | Reservoir | | | | | |
| West Basin Expansion, LA | 2006 | 6.5 | MF, RO, UV | Injection | | | | | |
| LA Harbor Project | 2006 | 6.5 | MF, RO | Injection | | | | | |
| Alamitos Gap, LA | 2005 | 3 | MF, RO, UV | Injection | | | | | |
| Western Corridor Recycled Water Project (Bundamba, Luggage Point, Gibson Island, Queensland) | 2007 | Up to 60 | MF, RO, UV | Reservoir | | | | | |
































discharges > 150 MGD Santa Ana River Water Quality and Health (SARWQH) Study 1994-2004



🕑 Imported Water Recharge

 Colorado River water and State Water Project water (from Sacramento/San Joaquin Delta)
 OCWD average 65,000 AFY

- (80 million m³/yr) imported water recharge mostly Colorado River water Imported water sources all
- Imported water sources all receive effluent discharges from upstream cities
- Replenishment water less available than past

